



City of Madison Site Plan Verification

PROJECT: LNDMAC-2017-00047

Address: 4110 Veith AVE

Current Revision #: 0

Submitted by: Marvin's Brick Pavers, Inc.

Contact: Marvin Martinez

Lispin123@gmail.com

Project Type: Minor Alteration to Approved Conditional Use

Description: Remove/replace retaining wall, remove concrete slab and replace with paver patio

Status: Approved

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Jeffrey Quamme	Jun 8 2017
Engineering Review Main Office	Approved	Brenda Stanley	Jun 26 2017
Planning Review	Approved	Kevin Firchow	Jul 25 2017
Zoning Review	Approved	Patrick Anderson	Jul 25 2017
Plan Director Review	Administrative Approval	Kevin Firchow	

ENGINEERING

Note **Comment Date:** 06/24/2017

Any added or revised plan sheets must be submitted to Zoning to be included in the official approved plan set.

Note **Comment Date:** 06/24/2017

Less than 4,000 sf disturbed area, no Erosion Control or Storm Water Management Permits required..

ZONING

Note **Comment Date:** 06/29/2017

Any disturbance of the soil on a property known to be associated with a burial site/archaeological site will have to comply with State Statute related to Burial Sites. Chip Brown chip.brown@wisconsinhistory.org or 264 6508.

Supplement Required **Comment Date:** 06/29/2017

Work with zoning staff to establish a compliance date with all the elements of the approved site plan subject to section 28.186(4)(b).