



City of Madison Site Plan Verification

PROJECT: LNDMAC-2018-00026

Address: 640 W Washington AVE

Current Revision #: 0

Submitted by: McFadden & Company

Contact: James McFadden
(608) 251-1350

Project Type: Minor Alteration to Approved Conditional Use

Description: Alt. to UMX district - parking lot expansion

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Jeffrey Quamme	Aug 4 2019
Engineering Review Main Office	Approved	Timothy Troester	Aug 26 2019
Fire Review	Approved	William Sullivan	May 11 2018
Landmarks Commission Review	Approved	Amy Scanlon	Mar 8 2018
Lighting Review	Approved	Steve Rewey	Oct 1 2019
Planning Review	Approved	Heather Stouder	Sep 24 2019
Traffic Engineering Review	Approved	Timothy Stella	May 2 2018
Urban Design Commission Review	Approved	Janine Glaeser	Mar 14 2018
Zoning Review	Approved	Christina Thiele	Oct 10 2019
Plan Director Review	Administrative Approval	Heather Stouder	

Submitted by: McFadden & Company**Contact:** James McFadden
(608) 251-1350**Project Type:** Minor Alteration to Approved Conditional Use**Description:** Alt. to UMX district - parking lot expansion**Status:** Closed**Revision History:** [0](#)**ENGINEERING****Supplement Accepted****Comment Date:** 03/05/2018

This project is subject to City of Madison erosion control permitting requirements. Submit completed permit application, permit fee, erosion control plan, USLE calculations, etc. to Megan Eberhardt for review and issuance of the required City of Madison Erosion Control Permit. Permit application forms can be found online at <http://www.cityofmadison.com/engineering/Permits.cfm>. Questions regarding erosion control permitting requirements can be sent to Megan at meberhardt@cityofmadison.com.

Supplement Accepted**Comment Date:** 03/05/2018

This project is subject to City of Madison stormwater management permitting requirements. Submit completed permit application, permit fee, stormwater management plan stamped by a Wisconsin P.E., modeling calculations, etc. to Megan Eberhardt for review and issuance of the required City of Madison Stormwater Management Permit. Permit application forms can be found online at <http://www.cityofmadison.com/engineering/Permits.cfm>. Questions regarding stormwater management requirements or stormwater permitting requirements can be sent to Megan at meberhardt@cityofmadison.com.

Supplement Accepted**Comment Date:** 03/05/2018

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Megan Eberhardt at Meberhardt@cityofmadison.com. The final document and fee should be submitted to City Engineering, attention: Megan Eberhardt.

Supplement Accepted**Comment Date:** 03/05/2018

Submit electronic data files for the stormwater management modeling and calculations. Files can be emailed to Megan Eberhardt at Meberhardt@cityofmadison.com or submitted on CD to City Engineering.

Supplement Accepted**Comment Date:** 03/05/2018

Submit PDFs of the final plans for Engineering records. Files can be emailed to Tim Troester at ttroester@cityofmadison.com or submitted on CD to City Engineering.

Supplement Accepted**Comment Date:** 03/05/2018

Submitted by: McFadden & Company**Contact:** James McFadden
(608) 251-1350**Project Type:** Minor Alteration to Approved Conditional Use**Description:** Alt. to UMX district - parking lot expansion**Status:** Closed**Revision History:** [0](#)

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Plat name and lot lines (metes & bounds parcel lines if unplatted)
- g) Platted lot numbers (noted "unplatted lands" if not platted)
- h) Lot/Plat property dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: ttroester@cityofmadison.com. The party responsible for the CAD file email transmission shall include the project site address in the email subject line. Any changes or additions to the location of the building, private utilities, sidewalks, parking/pavement during construction will require a new CAD file transmittal to City by applicant.

ENGINEERING MAPPING

Supplement Required

Comment Date: 03/08/2018

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Mapping Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names

All other levels (contours, setbacks, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

Submitted by: McFadden & Company**Contact:** James McFadden
(608) 251-1350**Project Type:** Minor Alteration to Approved Conditional Use**Description:** Alt. to UMX district - parking lot expansion**Status:** Closed**Revision History:** [0](#)**Supplement Accepted****Comment Date:** 03/09/2018

Revised plan provided 2018-8-23

In the area of the proposed new parking area, there is a Pedestrian Access Easement in that corner per paragraph B(2) of Document No. 2136371. The easement shall be shown, dimensioned and labeled and the connections to the adjacent pedestrian access facilities shown and clearly labeled.

Supplement Accepted**Comment Date:** 03/09/2018

Draft of configuration provided. Doc No 5506978

The Fire Department and Vehicular Access Easement per Paragraph B(1) of Doc No. 2136371 shall be shown on the site plan and the width labeled. It appears to not fit the current location of the access aisles of this site plan. If it does not match current conditions, an amendment to the easement shall be made and a recorded copy provided that locates the easement to the current aisle location.

FIRE**Supplement Accepted****Comment Date:** 03/07/2018

The site plans shall clearly identify the location of all fire lanes.
Per Sheet C800 dated 5-10-18

TRAFFIC ENGINEERING**Supplement Accepted****Comment Date:** 03/01/2018Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Tim Stella - tstella@cityofmadison.com**Supplement Accepted****Comment Date:** 03/01/2018

The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; ADA stall dimensions; secured parking facility; sidewalk dimensions; drive aisle dimensions; bike stall dimensions and detail; underground parking dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

Supplement Accepted**Comment Date:** 03/01/2018

Items in the Right-of-Way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the ROW that states: The Right-of-Way is the sole jurisdiction of the City of Madison and is subject to change at any time per the recommendation/plan of Traffic Engineering and City Engineering Departments.

Supplement Accepted**Comment Date:** 03/01/2018

The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet – 25 feet behind the property line at streets and 10 feet at driveways.). If applicant believes public safety can be maintained, they shall apply for a waiver of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the waiver shall be the determination of the City Traffic Engineer. Place and dimension all vision triangles in the proposed plan.

Submitted by: McFadden & Company**Contact:** James McFadden
(608) 251-1350**Project Type:** Minor Alteration to Approved Conditional Use**Description:** Alt. to UMX district - parking lot expansion**Status:** Closed**Revision History:** [0](#)**Supplement Accepted****Comment Date:** 03/01/2018

Secure parking facility. This is usually done with continuous six (6) inch curb, timbers, preformed wheel stops, guardrail erected at a height of eighteen (18) inches or fencing of sufficient strength to act as a vehicle bumper.

ZONING**Supplement Accepted****Comment Date:** 09/23/2019

Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Applicant provided the date June 1, 2020

Supplement Accepted**Comment Date:** 09/23/2019

Provide 4 accessible auto stalls and identify them on the site plan.

Supplement Accepted**Comment Date:** 09/23/2019

Update impervious surface calculations.