



City of Madison Site Plan Verification

PROJECT: LNDMAC-2018-00055

Address: 5706 Odana RD

Current Revision #: 0

Submitted by:

Contact:

Project Type: Minor Alteration to Approved Conditional Use

Description: Install trash enclosure

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Lori Zenchenko	Apr 30 2018
Engineering Review Main Office	Approved	Timothy Troester	May 5 2018
Fire Review	Approved	William Sullivan	May 16 2018
Planning Review	Approved	Heather Stouder	Jun 8 2018
Traffic Engineering Review	Approved	Timothy Stella	Jun 8 2018
Urban Design Commission Review	Approved	Janine Glaeser	May 7 2018
Zoning Review	Approved	Gregory Patmythes	Jun 8 2018
Plan Director Review	Administrative Approval	Heather Stouder	

Submitted by:

Contact:

Project Type: Minor Alteration to Approved Conditional Use

Description: Install trash enclosure

Status: Closed

Revision History: [0](#)**TRAFFIC ENGINEERING****Supplement Accepted****Comment Date:** 05/03/2018

Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Tim Stella - tstella@cityofmadison.com

Supplement Accepted**Comment Date:** 05/03/2018

The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; ADA/striped stall dimensions; secured parking facility; sidewalk dimensions; drive aisle dimensions; bike stall dimensions and detail; underground parking dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

Supplement Accepted**Comment Date:** 05/03/2018

Items in the Right-of-Way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the ROW that states: The Right-of-Way is the sole jurisdiction of the City of Madison and is subject to change at any time per the recommendation/plan of Traffic Engineering and City Engineering Departments.

Supplement Accepted**Comment Date:** 05/03/2018

The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet – 25 feet behind the property line at streets and 10 feet at driveways.). If applicant believes public safety can be maintained, they shall apply for a waiver of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the waiver shall be the determination of the City Traffic Engineer. Place and dimension all vision triangles in the proposed plan.

Supplement Accepted**Comment Date:** 05/03/2018

The applicant shall show dimensions for the proposed and existing parking stalls items S = 9 ft, L = 18 ft, E = 24 ft, F = 20 ft, and degree of angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b)2. Alternatively, use "Small Vehicles" parking design standards 10.08(6)(b)3 items S = 8.5", L = 16", E = 22' & F = 18' where all parking shall be clearly identified and properly controlled for use by only such vehicles.

ZONING**Supplement Accepted****Comment Date:** 05/04/2018

The enclosure, including the gate, shall be a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.

Note**Comment Date:** 05/04/2018

Please provide a completion date for the project. August 28, 2018.