



City of Madison Site Plan Verification

PROJECT: LNDMAC-2019-00002

Address: 802 Atlas AVE

Current Revision #: 0

Submitted by: Design Coalition Architects

Contact: Roger Smith
(608) 957-6773
roger@designcoalition.org

Project Type: Minor Alteration to Approved Conditional Use

Description: New temporary volleyball court, new bus parking stall, new exterior cooler, new fountain

Status: Plan Review in Process

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Add'l Info Req'd	Jeffrey Quamme	Jan 12 2019
Engineering Review Main Office	Add'l Info Req'd	Brenda Stanley	Jan 18 2019
Fire Review	Approved	William Sullivan	Jan 14 2019
Planning Review	Add'l Info Req'd	Heather Stouder	Jan 15 2019
Traffic Engineering Review	Approved	Timothy Stella	Jan 10 2019
Zoning Review	Pending	-	N/A
Plan Director Review			

ENGINEERING

Note **Comment Date:** 01/18/2019

Daniel Olivares (daolivares@cityofmadison.com) may have comments regarding possible erosion control and stormwater management measures.

ENGINEERING MAPPING

Supplement Required **Comment Date:** 01/12/2019

The walk in cooler will be within the public sanitary sewer easement. An amendment to the consent to occupy agreement will be required. Provide a detail of the new encroachment and \$500 fee to Jeff Quamme for the amendment.

PLANNING

Supplement Required **Comment Date:** 01/15/2019

Please submit written support from District 3 Alder, Amanda Hall.

Supplement Required **Comment Date:** 01/15/2019

Submit specifications of the proposed cooler and any proposed screening around it.