



## City of Madison Site Plan Verification

**PROJECT: LNDMAP-2017-00052**

**Address:** 8310 Globe DR

**Current Revision #: 0**

**Submitted by:** KNOTHE & BRUCE

**Contact:** DENISE SALIMES  
(608) 836-3690  
dsalimes@knothebruce.com

**Project Type:** Minor Alteration to Approved Planned Unit Development

**Description:** ADDED DOG RUN & IMPROVE POOL PLAZA

**Status:** Approved

**Revision History:** [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	<a href="#">Lori Zenchenko</a>	Dec 13 2017
Engineering Review Main Office	Approved	<a href="#">Timothy Troester</a>	Dec 18 2017
Fire Review	Approved	<a href="#">William Sullivan</a>	Dec 1 2017
Planning Review	Approved	<a href="#">Heather Stouder</a>	Dec 6 2017
Traffic Engineering Review	Approved	<a href="#">Timothy Stella</a>	Dec 13 2017
Urban Design Commission Review	Approved	<a href="#">Janine Glaeser</a>	Dec 12 2017
Zoning Review	Approved	<a href="#">Jenny Kirchgatter</a>	Dec 6 2017
<b>Plan Director Review</b>	Administrative Approval	<a href="#">Heather Stouder</a>	

**Submitted by:** KNOTHE & BRUCE  
**Contact:** DENISE SALIMES  
(608) 836-3690  
dsalimes@knothebruce.com  
**Project Type:** Minor Alteration to Approved Planned Unit Development  
**Description:** ADDED DOG RUN & IMPROVE POOL PLAZA  
**Status:** Approved  
**Revision History:** [0](#)

**ENGINEERING**

**Note** **Comment Date:** 12/18/2017

The Contractor will need to verify the depths that they are able to drive the fence posts for the dog run fencing when in close proximity to the underground stormwater system do avoid damage to the system.

**ENGINEERING MAPPING**

**Supplement Accepted** **Comment Date:** 12/01/2017

CAD received 12/12/2017.

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Mapping Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names

All other levels (contours, setbacks, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

**Note** **Comment Date:** 12/06/2017

The dog run area will lie above approved private underground storm water storage facilities

**TRAFFIC ENGINEERING**

**Supplement Accepted** **Comment Date:** 12/08/2017

Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Tim Stella - tstella@cityofmadison.com

**Supplement Accepted** **Comment Date:** 12/08/2017

Applicant shall submit a copy of all underground parking plans.