



City of Madison Site Plan Verification

PROJECT: LNDSPR-2013-00078

Address: 2222 S Park ST

Current Revision #: 0

Submitted by: City of Madison

Contact: Natalie Erdman
(608) 267-1992
nerdman@cityofmadison.com

Project Type: Permitted Use Site Plan Review

Description: Library/ Urban League- relocate accessible stalls and stripe out parking stall.

Status: Agency Reviews in Process

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Traffic Engineering Review	Add'l Info Req'd	Eric Halvorson	Jun 24 2013
Zoning Review	Approved	Jenny Kirchgatter	Jun 4 2013

TRAFFIC ENGINEERING

Supplement Required

Comment Date: 06/24/2013

The applicant shall show dimensions for the proposed and existing parking stalls items B = 9 ft, C = 18 ft, D = 36ft, E = 24 ft, F = 20 ft, and degree of angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2. Signs and planting areas are to be excluded from the rectangular stall areas including the two (2) feet of vehicle overhang. The two (2) feet of vehicle overhang shall be shown on the plan and dimensioned.