



City of Madison Site Plan Verification

PROJECT: LNDSPR-2017-00093

Address: 910 S High Point RD

Current Revision #: 0

Submitted by:

Contact:

Project Type: Permitted Use Site Plan Review

Description: Solar panel installation on well 26

Status: Approved

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Lori Zenchenko	Jun 29 2017
Engineering Review Main Office	Approved	Timothy Troester	Jul 20 2017
Fire Review	Approved	William Sullivan	Jun 29 2017
Traffic Engineering Review	Approved	Eric Poffenberger	Jul 18 2017
Urban Design Commission Review	Approved	Alan Martin	Jul 5 2017
Zoning Review	Approved	Gregory Patmythes	Jun 29 2017

TRAFFIC ENGINEERING

Supplement Accepted

Comment Date: 07/14/2017

Provide an electronic copy of the site plan, .pdf preferred, e-mail plan to Eric Poffenberger - epoffenberger@cityofmadison.com

Comment Date: 07/14/2017

Supplement Accepted

Comment Date: 07/14/2017

Applicant will update site plan to include existing features. Example: missing drive area.

Supplement Accepted

Comment Date: 07/14/2017

"Stop" signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.

ZONING

Note

Comment Date: 06/29/2017

Solar energy systems are permitted to encroach into a setback.