



City of Madison Site Plan Verification

PROJECT: LNDSPR-2017-00114

Address: 2301 Atwood AVE

Current Revision #: 0

Submitted by:

Contact: Victoria Kohlman
(608) 255-2800
rental2301@live.com

Project Type: Permitted Use Site Plan Review

Description: Addition of fence and cinderblock curb

Status: Agency Reviews in Process

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Jeffrey Quamme	Aug 11 2017
Engineering Review Main Office	Approved	Brenda Stanley	Aug 15 2017
Fire Review	Approved	William Sullivan	Aug 14 2017
Traffic Engineering Review	Add'l Info Req'd	Eric Poffenberger	Aug 18 2017
Zoning Review	Approved	Jacob Moskowitz	Sep 28 2017

ENGINEERING

Note **Comment Date:** 08/15/2017

Less than 4,000 sf disturbed area, no Erosion Control or Storm Water Management Permits required.

TRAFFIC ENGINEERING

Supplement Required **Comment Date:** 08/18/2017

Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Eric Poffenberger - epoffenberger@cityofmadison.com

Supplement Required **Comment Date:** 08/18/2017

"Stop" signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.