



City of Madison Site Plan Verification

PROJECT: LNDSPR-2018-00049

Address: 1002 Ann ST

Current Revision #: 0

Submitted by: Payne & Dolen

Contact: Colin Meisel

Project Type: Permitted Use Site Plan Review

Description: resurface existing parking lot and restore landscaping

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Add'l Info Req'd	Jeffrey Quamme	Mar 21 2022
Engineering Review Main Office	Add'l Info Req'd	Timothy Troester	Mar 21 2022
Fire Review	Approved	William Sullivan	Jun 14 2018
Traffic Engineering Review	Add'l Info Req'd	Timothy Stella	Mar 21 2022
Zoning Review	Add'l Info Req'd	Jacob Moskowitz	Mar 21 2022

Submitted by: Payne & Dolen**Contact:** Colin Meisel**Project Type:** Permitted Use Site Plan Review**Description:** resurface existing parking lot and restore landscaping**Status:** Closed**Revision History:** [0](#)**ENGINEERING****Supplement Required****Comment Date:** 05/23/2018

Tabulate land disturbance area and provide to City Engineering. Land disturbance of 4,000 square feet or more will trigger erosion control permitting requirements and may trigger stormwater management requirements. For 20,000 square feet or more of land disturbance a detailed erosion control plan is required as well.

If the project disturbs 4,000 square feet or more of land area, it will be subject to City of Madison erosion control permitting requirements. Submit completed permit application, permit fee, and USLE calculations to Megan Eberhardt for review and issuance of the required City of Madison Erosion Control Permit. If 20,000 square feet or more of land disturbance is required for the project also submit a site specific erosion control plan. Permit application forms can be found online at <http://www.cityofmadison.com/engineering/Permits.cfm>. Questions regarding erosion control permitting requirements can be sent to Megan at meberhardt@cityofmadison.com.

Supplement Required**Comment Date:** 05/23/2018

Provide total mill and overlay pavement area. Per Madison General Ordinance Chapter 37.06(3)(g) any site improvement project that requires zoning approval and had 30,000 square feet or more of parking lot resurfacing is subject to stormwater management performance standards of MGO 37.09(1), (2), (3)(a) and (3)(b). This requires the submittal of a stormwater management report and the implementation of stormwater management practices for TSS control and oil/grease control.

If this project is subject to City of Madison stormwater management permitting requirements due to either land disturbance equal to or exceeding 4,000 square feet or parking lot resurfacing of 30,000 square feet or more plan updates and stormwater submittals will be required to show how these requirements are being met. Submit completed permit application, permit fee, stormwater management plan stamped by a Wisconsin P.E., modeling calculations, etc. to Megan Eberhardt for review and issuance of the required City of Madison Stormwater Management Permit. Permit application forms can be found online at <http://www.cityofmadison.com/engineering/Permits.cfm>. Questions regarding stormwater management requirements or stormwater permitting requirements can be sent to Megan at meberhardt@cityofmadison.com.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Megan Eberhardt at Meberhardt@cityofmadison.com. The final document and fee should be submitted to City Engineering, attention: Megan Eberhardt.

Submit electronic data files for the stormwater management modeling and calculations. Files can be emailed to Megan Eberhardt at Meberhardt@cityofmadison.com or submitted on CD to City Engineering.

Supplement Required**Comment Date:** 05/23/2018

Submit PDFs of the final plans for Engineering records. Files can be emailed to Tim Troester at ttroester@cityofmadison.com or submitted on CD to City Engineering.

Supplement Required**Comment Date:** 05/23/2018

Submitted by: Payne & Dolen**Contact:** Colin Meisel**Project Type:** Permitted Use Site Plan Review**Description:** resurface existing parking lot and restore landscaping**Status:** Closed**Revision History:** [0](#)

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Plat name and lot lines (metes & bounds parcel lines if unplatted)
- g) Platted lot numbers (noted "unplatted lands" if not platted)
- h) Lot/Plat property dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: ttroester@cityofmadison.com. The party responsible for the CAD file email transmission shall include the project site address in the email subject line. Any changes or additions to the location of the building, private utilities, sidewalks, parking/pavement during construction will require a new CAD file transmittal to City by applicant.

ENGINEERING MAPPING

Supplement Required

Comment Date:

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Mapping Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names

All other levels (contours, setbacks, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

Submitted by: Payne & Dolen

Contact: Colin Meisel

Project Type: Permitted Use Site Plan Review

Description: resurface existing parking lot and restore landscaping

Status: Closed

Revision History: [0](#)

Supplement Required**Comment Date:**

Remove adjacent motel building outline on all plan sheets. Building was demolished in 2017.

TRAFFIC ENGINEERING**Supplement Required****Comment Date:** 06/15/2018

Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Tim Stella - tstella@cityofmadison.com

Supplement Required**Comment Date:** 06/15/2018

The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; ADA/striped stall dimensions; secured parking facility; sidewalk dimensions; drive aisle dimensions; bike stall dimensions and detail; underground parking dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

Supplement Required**Comment Date:** 06/15/2018

Items in the Right-of-Way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the ROW that states: The Right-of-Way is the sole jurisdiction of the City of Madison and is subject to change at any time per the recommendation/plan of Traffic Engineering and City Engineering Departments.

Supplement Required**Comment Date:** 06/15/2018

The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet – 25 feet behind the property line at streets and 10 feet at driveways.). If applicant believes public safety can be maintained, they shall apply for a waiver of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the waiver shall be the determination of the City Traffic Engineer. Place and dimension all vision triangles in the proposed plan.

Supplement Required**Comment Date:** 06/15/2018

Secure parking facility. This is usually done with continuous six (6) inch curb, timbers, preformed wheel stops, guardrail erected at a height of eighteen (18) inches or fencing of sufficient strength to act as a vehicle bumper.

Supplement Required**Comment Date:** 06/15/2018

Applicant shall provide a copy of all cross access agreements. Email to tstella@cityofmadison.com

Supplement Required**Comment Date:** 06/15/2018

Stop signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.

Supplement Required**Comment Date:** 06/15/2018

Dimensions of the driveways shall be noted on the plan including the width of driveway and width of driveway flares or curb cut.

ZONING

Submitted by: Payne & Dolen**Contact:** Colin Meisel**Project Type:** Permitted Use Site Plan Review**Description:** resurface existing parking lot and restore landscaping**Status:** Closed**Revision History:** [0](#)**Supplement Required****Comment Date:** 07/13/2018

Submit a landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.

Supplement Required**Comment Date:** 07/13/2018

Show the trash enclosure area on the site plan. All developments, except single family and two family developments, shall provide a refuse disposal area. Such area shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet. Submit a detail of the trash enclosure.

Supplement Required**Comment Date:** 07/13/2018

Bicycle parking for the project shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance. Note: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.

Note**Comment Date:** 07/13/2018

Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.