



City of Madison Site Plan Verification

PROJECT: LNDSPR-2018-00101

Address: 201 S Gammon RD

Current Revision #: 0

Submitted by: Forward Electric

Contact: Jenn Luhman
(608) 221-1945
jennifer@forwardelectric.com

Project Type: Permitted Use Site Plan Review

Description: Updating lighting for Memorial High School's football and baseball fields

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Lighting Review	Approved	Steve Rewey	Aug 2 2018
Urban Design Commission Review	Approved	Janine Glaeser	Aug 6 2018
Zoning Review	Approved	Christina Thiele	Jul 31 2018

URBAN DESIGN COMMISSION

Note **Comment Date:** 08/06/2018

Building Plan review team to confirm no light trespass and full light cut-off fixtures.

ZONING

Supplement Accepted **Comment Date:** 07/30/2018

Submit \$50 site plan review fee. Checks are made out to City of Madison.

Supplement Accepted **Comment Date:** 07/30/2018

Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Applicant provided the date 9/1/18