



City of Madison Site Plan Verification

PROJECT: LNDSPR-2018-00102

Address: 3326 Agriculture DR

Current Revision #: 0

Submitted by: Strand Associates, Inc.

Contact: Jim Ternus
608-251-2129 X1167
jim.ternus@strand.com

Project Type: Permitted Use Site Plan Review

Description: South truck dock and loading pavement addition

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Lori Zenchenko	Aug 23 2018
Engineering Review Main Office	Approved	Daniel Olivares	Sep 7 2018
Fire Review	Approved	William Sullivan	Aug 10 2018
Lighting Review	Approved	Steve Rewey	Aug 8 2018
Traffic Engineering Review	Approved	Timothy Stella	Aug 8 2018
Urban Design Commission Review	Approved	Janine Glaeser	Aug 6 2018
Zoning Review	Approved	Patrick Anderson	Aug 17 2018

Submitted by: Strand Associates, Inc.
Contact: Jim Ternus
608-251-2129 X1167
jim.ternus@strand.com
Project Type: Permitted Use Site Plan Review
Description: South truck dock and loading pavement addition
Status: Closed
Revision History: [0](#)

ENGINEERING**Supplement Accepted****Comment Date:** 08/16/2018

The Applicant shall submit, prior to plan sign-off but after all revisions are completed, a digital CAD file (single file) to the Engineering Division (storm/sanitary section). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number: a) Building Footprints, b) Internal Walkway Areas, c) Internal Site Parking Areas, d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.), e) Right-of-Way lines (public and private), f) Plat name and lot lines (metes & bounds parcel lines if unplatted), g) Platted lot numbers (noted "unplatted lands" if not platted), h) Lot/Plat property dimensions, i) Street names, j) Private on-site sanitary sewer utilities (including all connections to public sanitary), k) Private on-site storm sewer utilities (including all connections to public storm)
THE CAD FILE WILL ONLY BE REQUIRED PRIOR TO FINAL PLAN REVIEW SO THAT MULTIPLE FILES DO NOT NEED TO BE SUPPLIED OR REVIEWED.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com. The party responsible for the CAD file email transmission shall include the project site address in the email subject line. Any changes or additions to the location of the building, private utilities, sidewalks, parking/pavement during construction will require a new CAD file transmittal.

Supplement Accepted**Comment Date:** 08/16/2018

The applicant shall submit, prior to plan sign-off but after all revisions are completed, digital PDF files to the Engineering Division (bstanley@cityofmadison.com). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2)). PDF submittals shall contain the following information: a) Building footprints, b) Internal walkway areas, c) Internal site parking areas, d) Lot lines and right-of-way lines, e) Street names, f) Stormwater Management Facilities, g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans), h) Private on-site sanitary sewer utilities (including all connections to public sanitary), i) Private on-site storm sewer utilities (including all connections to public storm).

Supplement Accepted**Comment Date:** 08/16/2018

This site will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Please submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Daniel Olivares (daolivares@cityofmadison.com), City Engineering, for approval.

Supplement Accepted**Comment Date:** 08/22/2018

This site will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Daniel Olivares (daolivares@cityofmadison.com) at City Engineering.

Supplement Accepted**Comment Date:** 08/22/2018

This site will require a Storm Water Management Permit. Please submit the Storm Water Management Permit Application (and associated fee) to Daniel Olivares (daolivares@cityofmadison.com), City Engineering, for approval.

Supplement Accepted**Comment Date:** 08/22/2018

The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including: a) SLAMM DAT files b) RECARGA files c) TR-55/HYDROCAD/Etcd) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2)) Contact Daniel Olivares, City Engineering, at daolivares@cityofmadison.com.

Submitted by: Strand Associates, Inc.
Contact: Jim Ternus
608-251-2129 X1167
jim.ternus@strand.com
Project Type: Permitted Use Site Plan Review
Description: South truck dock and loading pavement addition
Status: Closed
Revision History: [0](#)

Supplement Accepted**Comment Date:** 08/22/2018

Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to reduce TSS by 80% (control the 5 micron particle) off of newly developed areas compared to no controls.

Supplement Accepted**Comment Date:** 08/22/2018

Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to detain the 2, 10, & 100 -year storm events, matching post development rates to predevelopment rates.

Supplement Accepted**Comment Date:** 08/22/2018

Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to provide oil/grease

Supplement Accepted**Comment Date:** 08/29/2018

This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>

ENGINEERING MAPPING**Supplement Accepted****Comment Date:**

CAD received 8/23/2018.

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Mapping Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names

All other levels (contours, setbacks, elevations, etc) are not to be included with this file submittal.

NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

URBAN DESIGN COMMISSION

Submitted by: Strand Associates, Inc.

Contact: Jim Ternus
608-251-2129 X1167
jim.ternus@strand.com

Project Type: Permitted Use Site Plan Review

Description: South truck dock and loading pavement addition

Status: Closed

Revision History: [0](#)

Note **Comment Date:** 08/06/2018

Proposed site changes generally meet UDD #1 design requirements.

Note **Comment Date:** 08/06/2018

Provide light fixture cut sheets with permit application.

ZONING

Supplement Accepted **Comment Date:** 08/01/2018

Provide a compliance date with all elements of the approved site plan subject to section 28.186(4)(b). December 31, 2018 being that date.

Note **Comment Date:** 08/01/2018

Provide to the zoning counter three copies of any revised plan sheets.