



City of Madison Site Plan Verification

PROJECT: LNDSPR-2018-00140

Address: 66 West Towne MALL

Current Revision #: 0

Submitted by: Srb Trees Inc

Contact: Joe Srb
(608) 698-3376
srbtrees@charter.net

Project Type: Permitted Use Site Plan Review

Description: Temporary Use Permit for a Christmas tree sale

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Fire Review	Approved	William Sullivan	Nov 13 2018
Traffic Engineering Review	Approved	Timothy Stella	Nov 13 2018
Zoning Review	Approved	Christina Thiele	Nov 12 2018

FIRE

Note **Comment Date:** 11/13/2018

A second emergency exit shall be provided at least 25-ft away from the primary entrance when the capacity exceeds 49 occupants. (customers & employees)

Note **Comment Date:** 11/13/2018

All obstructions include the site fencing shall be a minimum of 5-ft from the main drive aisles.