



# City of Madison Site Plan Verification

**PROJECT: LNDUSE-2018-00030**

**Address:** 2911 N Sherman AVE

**Current Revision #: 0**

**Submitted by:** Bierock

**Contact:** Brian & Amanda Carriveau  
(608) 334-3471  
amanda@bierockmadison.com

**Project Type:** Land Use

**Description:** Allow outdoor eating area for restaurant-tavern.

**Status:** Closed

**Revision History:** [0](#)

Review	Status	Reviewer	Reviewed
Fire Review	Approved	<a href="#">William Sullivan</a>	Jun 26 2018
Planning Review	Approved	<a href="#">Colin Punt</a>	Jun 15 2018
Zoning Review	Approved	<a href="#">Jenny Kirchgatter</a>	Jun 29 2018

## ZONING VERIFICATION

**Supplement Accepted**

**Comment Date:** 06/25/2018

Submit payment for \$100 review fee.

**Supplement Accepted**

**Comment Date:** 06/29/2018

Bicycle parking shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Provide a minimum of five (5) short-term bicycle parking stalls located in a convenient and visible area on a paved or impervious surface. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance. If existing bicycle stalls are located within 100 feet of the entrance, identify the stalls on the site plan and provide the number of stalls. Note: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.