



City of Madison Site Plan Verification

PROJECT: LNDUSE-2018-00061

Address: 2901 Atwood AVE

Current Revision #: 0

Submitted by: McCaughey Properties LLC

Contact: Patrick McCaughey
(608) 516-9497

Project Type: Land Use

Description: Demolish 5-unit apartment building to construct 9-unit apartment building.

Status: Closed

Revision History: [0](#)

Review	Status	Reviewer	Reviewed
Engineering Mapping	Approved	Lori Zenchenko	Nov 5 2018
Engineering Review Main Office	Add'l Info Req'd	Brenda Stanley	Feb 18 2022
Fire Review	Approved	William Sullivan	Aug 23 2018
Parks/Forestry Review	Approved	Kathleen Kane	Dec 14 2018
Planning Review	Approved	Colin Punt	Sep 10 2018
Recycling Coordinator	Pending	Bryan Johnson	Pending
Traffic Engineering Review	Add'l Info Req'd	Timothy Stella	Feb 18 2022
Water Utility Review	Approved	Adam Wiederhoeft	Oct 10 2018
Zoning Review	Add'l Info Req'd	Jenny Kirchgatter	Feb 18 2022

Submitted by: McCaughey Properties LLC**Contact:** Patrick McCaughey
(608) 516-9497**Project Type:** Land Use**Description:** Demolish 5-unit apartment building to construct 9-unit apartment building.**Status:** Closed**Revision History:** [0](#)

ENG MAPPING VERIFICATION

Supplement Accepted**Comment Date:** 08/24/2018

The address of the proposed building is 2905 Atwood Ave.

The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

Supplement Accepted**Comment Date:** 08/24/2018

10/8/2018 submitted.

An addressing plan was not submitted and approved as required by the conditions of approval.

Submit a Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan for each floor on a separate sheet for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the application submittal for the final Site Plan Approval with Zoning. The approved Addressing Plan shall be included in the final application. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

Supplement Accepted**Comment Date:** 08/24/2018

CAD received 11/4/2018.

The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Mapping Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number: a) Building Footprints b) Internal Walkway Areas c) Internal Site Parking Areas d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.) e) Right-of-Way lines (public and private) f) Lot lines or parcel lines if unplatted g) Lot numbers or the words unplatted h) Lot/Plat dimensions i) Street names All other levels (contours, setbacks, elevations, etc) are not to be included with this file submittal. NOTE: Email file transmissions preferred lzenchenko@cityofmadison.com. Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.

Supplement Accepted**Comment Date:** 08/24/2018

CSM 14940 recorded 10/4/2018 as Doc # 5445645. 2905 Atwood Ave, 0710-053-2626-2.

The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD) prior to issuance of any building permits for new construction. When the recorded CSM image is available from the ROD, the Assessor's Office can then create the new Address-Parcel-Owner (APO) data in GEO so that the Accela system can upload this data and permit issuance made available for this new land record

ENGINEERING VERIFICATION

Supplement Required**Comment Date:** 08/28/2018

Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))

Submitted by: McCaughey Properties LLC**Contact:** Patrick McCaughey
(608) 516-9497**Project Type:** Land Use**Description:** Demolish 5-unit apartment building to construct 9-unit apartment building.**Status:** Closed**Revision History:** [0](#)

Supplement Accepted**Comment Date:** 08/28/2018

PAID \$117.98, 9/26/18

All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))

Supplement Accepted**Comment Date:** 08/28/2018

The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

Supplement Accepted**Comment Date:** 08/28/2018

The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2))PDF submittals shall contain the following information:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Stormwater Management Facilities
- k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

Submitted by: McCaughey Properties LLC**Contact:** Patrick McCaughey
(608) 516-9497**Project Type:** Land Use**Description:** Demolish 5-unit apartment building to construct 9-unit apartment building.**Status:** Closed**Revision History:** [0](#)**Supplement Accepted****Comment Date:** 08/28/2018

This site accepts stormwater runoff from a large area, and currently has a small enclosed depression within the parking lot. The new plan shall show how this water runoff shall be passed through the site to the Public ROW.

Note**Comment Date:** 08/28/2018

For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)

Supplement Required**Comment Date:** 08/28/2018

The Applicant shall Construct Sidewalk to a plan approved by the City. The construction of this project will require that the applicant shall enter into a City / Developer agreement for the required infrastructure improvements. The applicant shall contact City Engineering to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. Obtaining a developer's agreement generally takes approximately 4-6 weeks, minimum. Contact Brenda Stanley at bstanley@cityofmadison.com

Supplement Accepted**Comment Date:** 08/28/2018

This site will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Please submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Daniel Olivares (daolivares@cityofmadison.com), City Engineering, for approval.

Supplement Accepted**Comment Date:** 09/13/2018

The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.

Supplement Accepted**Comment Date:** 09/13/2018

This project will require a concrete management plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office.

Supplement Accepted**Comment Date:** 09/13/2018

This project appears to require construction dewatering. A dewatering plan shall be submitted to City Engineering as part of the Erosion Control Permit application and plan. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. Contact Daniel Olivares, City Engineering, at daolivares@cityofmadison.com.

TE VERIFICATION**Supplement Accepted****Comment Date:** 08/24/2018

Provide a revised electronic copy of the site plan, .pdf preferred, e-mail plan to Tim Stella - tstella@cityofmadison.com

Supplement Accepted**Comment Date:** 08/24/2018

Submitted by: McCaughey Properties LLC**Contact:** Patrick McCaughey
(608) 516-9497**Project Type:** Land Use**Description:** Demolish 5-unit apartment building to construct 9-unit apartment building.**Status:** Closed**Revision History:** [0](#)

The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; ADA/striped stall dimensions; secured parking facility; sidewalk dimensions; drive aisle dimensions; bike stall dimensions and detail; underground parking dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

Supplement Required**Comment Date:** 08/24/2018

A deposit of \$500 payable to City Treasurer will be required for the installation of traffic signage and markings deemed necessary with the completion of the development. Make check payable to the City of Madison Treasurer to be delivered or mailed to Attention Tim Stella, Traffic Engineering Department, 215 Martin Luther King Jr. Blvd; Suite 109, P.O. Box 2986, Madison, Wisconsin 53703-2986.

Supplement Required**Comment Date:** 08/24/2018

The Driveway Approach form will be filled out in the Traffic Engineering Office and requires only the fee / deposit to be paid as noted prior to site approval. The Driveway Approach Fee of \$100 is payable to the City of Madison Treasurer to be delivered or mailed to Attention Tim Stella, Traffic Engineering Department, 215 Martin Luther King Jr. Blvd; Suite 109, P.O. Box 2986, Madison, Wisconsin 53703-2986.

Supplement Accepted**Comment Date:** 08/24/2018

The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet – 25 feet behind the property line at streets and 10 feet at driveways.). If applicant believes public safety can be maintained, they shall apply for a waiver of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the waiver shall be the determination of the City Traffic Engineer. Place and dimension all vision triangles in the proposed plan.

Note**Comment Date:** 08/24/2018

Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.

Note**Comment Date:** 08/24/2018

The applicant shall dedicate the appropriate Right of Way to allow for a thirteen (13) foot sidewalk/terrace (six (6) foot terrace, six (6) foot sidewalk and one (1) foot from back of sidewalk for maintenance) adjacent the Atwood Avenue property line.

WATER UTILITY VERIFICATION**Supplement Accepted****Comment Date:** 09/03/2018

On 9/6/2018 MWU conducted an inspection of the residence and property at 2901 Atwood Ave and did not find any indications of a private well (both inside and outside of the structure).

A private well may have served this parcel prior to the municipal water service connection. Any remaining unused/unpermitted private wells existing on this parcel must be properly abandoned according to Wisconsin Administrative Code NR 812 and Madison General Ordinance 13.21 prior to the demolition of the property. Please contact water utility staff at (608) 266-4654 to schedule an on-site private well survey prior to demolition, otherwise for additional information regarding well abandonment procedures and potential well abandonment reimbursement programs.

Submitted by: McCaughey Properties LLC**Contact:** Patrick McCaughey
(608) 516-9497**Project Type:** Land Use**Description:** Demolish 5-unit apartment building to construct 9-unit apartment building.**Status:** Closed**Revision History:** [0](#)**Note****Comment Date:** 09/03/2018

The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Note**Comment Date:** 09/03/2018

A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

ZONING VERIFICATION**Supplement Required****Comment Date:** 09/11/2018

Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).

Supplement Accepted**Comment Date:** 10/08/2018

Provide a detail of the proposed permeable pavers.

Supplement Accepted**Comment Date:** 09/17/2018

The final site compliance date is May 31, 2020.

Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Note**Comment Date:** 09/17/2018

Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.